

TABLE I

Minimum Distance in Feet From	Closed Portion of Treatment System (1)	Open Portion of Treatment System (2)
Private water supply well	50	100
Public water supply well	200	200
Groundwater heat pump borehole	50	100
Lake or reservoir	50	100
Stream or pond	25	25
Edge of drainage ditch	10	10
Dwelling or other structure	10	10
Property lines (unless a mutual easement is signed and recorded)	10	10
Other type subsurface treatment system	5	10
Water lines continually under pressure	10	10
Suction water lines	50	100
Foundation drains or subsurface tiles	10	10

(1) Includes septic tanks, mechanical aeration tanks and impervious vault toilets.

(2) Includes subsurface absorption systems, mound systems, intermittent sand filters, constructed wetlands or waste stabilization ponds.

This information is taken from page 5 of Chapter 69 of the Iowa State Regulations for on-site wastewater treatment and sewage disposal systems.